



EXAMPLE

ONLY

SUBMIT

FOR

REVISION

ASPHALT SHINGLES
15/32" SHEATHING WITH
8D NAILS AT 6" O.C.
15 lb. FELT PAPER
2X6 RAFTERS @ 16" O.C.
HURRICANE CLIPS AT EACH
RAFTER ON OUTSIDE OF WALL

METAL EAVE DRIP
1X8 FASCIA

1/2" PLYWOOD SOFFIT
2" CONTINUOUS ALUMINUM VENT

15/32" SHEATHING WITH 8D
NAILS AT 3" O.C. AT EDGES
& 12" O.C. IN FIELD
WOOD SIDING

5/8" ANCHOR BOLTS WITH 3x3x3
GAGE WASHERS AT 16" O.C. WITH 7"
MIN. EMBED. ALSO PROVIDE ANCHOR
6" TO 12" FROM END OF EACH PLATE

8" CMU CORE FILLED
APPROXIMATE GRADE

F.F.E. TO MATCH
EXISTING F.F.E.

2X6 CEILING JOISTS @ 16" O.C.
R30 INSULATION
1/2" GYP. BOARD

SIMPSON HDU4 HOLD DOWN
ANCHOR AT ENDS OF EACH
SHEAR WALL SECTION

R13 INSULATION

3/4" PLYWOOD DECKING
2X6 FLOOR JOISTS @ 16" O.C.
P.T. IF LESS THAN 18" FROM GRADE

(1) #5 CONT.

R30 INSULATION
TREATED AND COMPACTED FILL

#5 @ 8' O.C.

TYPICAL WALL SECTION
SCALE 1"=1'-0"

1'-0" MINIMUM

1'-0" MINIMUM

(2) #5 CONT.